

2019

## DRINKING WATER QUALITY REPORT



## CONSUMER CONFIDENCE REPORT

**PWS ID: TX0360027**

## WOODLAND ACRES SUBDIVISION

### **Our Drinking Water Meets All Federal (EPA)**

#### **Drinking Water Requirements**

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. The U.S. Environmental Protection Agency (EPA) requires ongoing tests of all public water systems, and the results are provided on the following pages. We hope that by this information helps you to become more aware of what's in your drinking water in Woodland Acres Subdivision.

#### **Water Sources**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Contaminants may be found in drinking water that may cause taste, color or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office. In order to ensure that tap water is safe to drink, the EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

### **Special Notice for Infants, Elderly and those with Special Health Circumstances**



You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline at (800) 426-4791.

#### **En Espanol**

Este reporte incluye información importante sobre el agua potable. Para asistencia en español, favor de llamar por telefono a Corina al 281-355-1312.

#### **Public Participation Opportunities**

You may mail comments to:

Gulf Utility Service, Inc.

Attn: Woodland Acres Subdivision

P.O. Box 691008

Houston, TX 77269

#### **Where do we get our drinking water?**

The source of drinking water used by Woodland Acres Subdivision is Ground Water. It comes from the Chicot Aquifer. TCEQ completed an assessment of your source water and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact 281-355-1312.

**All Drinking Water May Contain Contaminants**

When drinking water meets federal standards there may not be any health benefits to purchasing bottled water or point of use devices. Drinking water, including bottled water, may reasonably be expected to contain at least small amount of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be found by calling the EPA’s Safe Drinking Water Hotline (1-800-426-4791).

**About this report**

This report lists all of the federally regulated or monitored contaminants which have been found in your drinking water. The U.S. EPS requires water systems to test for up to 97 contaminants. Most sampling is conducted at each source water entry point into the system. The actual water received by a consumer may be a blend from different sources, depending on location.

**Drinking Water Abbreviations and Definitions**

**Ave:** Regulatory compliance with some MCLs are based on running annual average of monthly samples.

**MFL:** million fibers per liter (a measure of asbestos)

**N/A:** not applicable

**NTU:** nephelometric turbidity units (a measure of turbidity)

**pCi/L:** picocuries per liter (a measure of radioactivity)

**ppm:** parts per million, or milligrams per liter (mg/L), or one ounce in 7,350 gallons of water

**ppb:** parts per billion, or micrograms per liter, or one ounce in 7,350,000 gallons of water

**ppt:** parts per trillion, or nanograms per liter (ng/L)

**ppq:** parts per quadrillion, or pictograms per liter (pg/L)

**Level 1 Assessment:**

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:**

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E.coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**Maximum Contaminant Level Goal or MCLG:**

The level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Contaminant Level or MCL:**

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology

**Maximum residual disinfectant level goal or MRDLG:**

There is a level of drinking water disinfectant below which there is no known or expected risk to health. MRDLs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Maximum residual disinfectant level or MRDL:**

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Mrem/year:** millirems per year (a measure of radiation absorbed by the body)

**Treatment Technique or TT:**

A required process intended to reduce the level of a contaminant in drinking water.

**Regulated Contaminants**

Disinfectants and Disinfection By-Products	Collection Date	Units	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Violation	Likely Source of Contamination
<b>Haloacetic Acids (HAA5)</b>	2019	ppb	18	10.4 – 17.5	No goal for the total	60	No	By-product of drinking water disinfection.
* The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year'								
<b>Total Trihalomethanes (TTHM)</b>	2019	ppb	63	62.4 – 63.1	No goal for the total	80	No	By-product of drinking water disinfection.
* The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year'								
Inorganic Contaminants	Collection Date	Units	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Violation	Likely Source of Contamination
<b>Arsenic*</b>	2019	ppb	9	8.2 – 9.4	0	10	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
<b>Barium</b>	2018	ppm	0.0585	0.0585 – 0.0585	2	2	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
<b>Fluoride**</b>	2018	ppm	2.58	2.58 – 2.58	4	4.0	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
<b>Nitrate [measured as Nitrogen]</b>	2018	ppm	0.01	0 – 0.01	10	10	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
*While your drinking water meets EPA standards for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.								
**This is an alert about your drinking water and a cosmetic dental problem that might affect children under nine years of age. At low levels, fluoride can help prevent cavities, but children drinking water containing more than 2 milligrams per liter (mg/L) of fluoride may develop cosmetic discoloration of their permanent teeth (dental fluorosis). The drinking water provided by your community water system Woodland Acres Subdivision has a fluoride concentration of 2.58 mg/L.'								
'Dental fluorosis, in its moderate or severe forms, may result in a brown staining and/or pitting of the permanent teeth. This problem occurs only in developing teeth, before they erupt from the gums. Children under nine should be provided with alternative sources of drinking water or water that has been treated to remove the fluoride to avoid the possibility of staining and pitting of their permanent teeth. You may also want to contact your dentist about proper use by young children of fluoride-containing products. Older children and adults may safely drink the water.'								
'For more information, please call <b>Gulf Utility Service, Inc. of Woodland Acres Subdivision</b> at <b>281-355-1312</b> . Some home water treatment units are also available to remove fluoride from drinking water. To learn more about available home water treatment units, you may call NSF International at 1-877-8-NSF-HELP.'								
Radioactive Contaminants	Collection Date	Units	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Violation	Likely Source of Contamination
<b>Combined Radium 226/228</b>	2018	pCi/L	1.5	1.5 – 1.5	0	5	No	Erosion of natural deposits.

**Disinfectant Residuals**

Year	Contaminant Unit of Measure	Average Level Detected	Range of Level Detected	MRDL	MRDLG	Violation	Likely Source of Contamination
2019	Free Chlorine	1.54	0.39 – 2.40	4	4	No	Water additive used to control microbes.

Lead & Copper								
Lead and Copper	Date Sampled	Units	90 <sup>th</sup> Percentile	MCLG	Action Level (AL)	# Sites over AL	Violation	Likely Source of Contamination
Lead	2017	ppb	4	0	15	0	No	Corrosion of household plumbing systems; Erosion of natural deposits.
Copper	2017	ppm	0.53	1.3	1.3	0	No	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.

TCEQ completed an assessment of your source water and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact 281-355-1312.

#### Additional Health Information for Lead

All water systems are required by EPA to report the following language: *"If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>."*