

ALBURY MANOR UTILITY CO.

2021 Drinking Water Quality Report

OUR DRINKING WATER IS SAFE

The Texas Commission on Environmental Quality (TCEQ), has assessed our system and determined that our water is safe to drink. The analysis was made by using the data in the attached tables. Your water meets federal standards set forth by the USEPA, there may not be health based benefits to purchasing bottled water or point of use devices.

En Español

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda.

Where do we get our drinking water?

Our drinking water is obtained from ground water sources. It comes from the Gulf Coast Aquifers some 500 to 2,000 feet below ground surface. TCEQ completed an assessment of your source water and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact Natalia Epitia at 281-353-9809.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

Special Notice for the ELDERLY, INFANTS, CANCER PATIENTS, people with HIV/AIDS or other immune problems:

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or Immuno-compromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from Safe Drinking Water Hotline (800-426-4791).

Contaminants that may be Present in Source Water

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic system, agricultural livestock operations, and wildlife;
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water, runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming;
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses;
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA prescribes regulations that limits the amount of certain contaminants in water provided by public water systems. Federal Food and Drug Administration Agency regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

Our drinking water is delivered by wells from underground aquifers that are protected from many of the sources of contamination described.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791

EPA website: www.epa.gov/safewater



Trusted Utility Partners

Public input concerning your water system may be made by contacting Natalia Espitia, h2o innovation at 281-353-9809 with any concerns or questions you may have.

About the Following Table

The following table contains all of the chemical constituents which have been found in your drinking water for the most recent testing performed in accordance with applicable regulations. USEPA requires water systems to test up to 97 constituents. The constituents detected in your water are listed in the attached table. **It is important to note that all of the water supplied to Albury Manor during 2021 came from Harris County M.U.D. No. 401. The information on the chemical constituents in the water from Harris County M.U.D. 401 is listed on page three of this report.**

DEFINITIONS

Maximum Contaminant Level (MCL) - The highest level of a contaminant in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected health risk. MCLG's allow for a margin of safety.

Treatment Technique - A required process intended to reduce the level of a contaminant in drinking water.

Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

ppm = parts per million or milligrams per liter (mg/l), one part per million corresponds to one minute in two years or a single penny in \$10,000.

ppb = parts per billion or micrograms per liter (mg/l), one part per billion corresponds to one minute in 2,000 years or a single penny in \$10,000,000.

pCi/l = pico curies per liter: Measure of radioactivity.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Albury Manor Utility Company - 2021 Drinking Water Quality Report

Organic Contaminants							
Year	Contaminant	Average Level Detected	Range of Detected Levels	MCL	MCLG	Unit of Measure	Source of Contaminant
2019	Total Trihalomethanes	26.9	26.9 - 26.9	80	0	ppb	By-product of drinking water chlorination.
2019	Haloacetic Acid (HAA5)	2.8	2.8 - 2.8	60	0	ppb	By-product of drinking water chlorination.

Disinfectant Residuals							
Year	Contaminant	Highest Average	Range of Detected Levels	MRDL	MCLG	Unit of Measure	Source of Contaminant
2021	Chlorine Disinfectant	1.72	0.48 - 4.5	4	0	ppm	Disinfectant used to control microbes.

Lead and Copper							
Year	Contaminant	90th Percentile	Number of Sites Exceeding Action Level	Action Level	MCLG	Unit of Measure	Source of Contaminant
2020	Lead	0.687	0	15	0	ppm	Corrosion of household plumbing Systems.
2020	Copper	0.0656	0	1.3	1.3	ppm	Corrosion of household plumbing Systems.

The 90th percentile of the Lead/ Copper analysis means the top 10% (highest sample results) of all samples collected.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>

Unregulated Contaminants**

Year	Contaminant	Average of All Sampling Points	Range of Detected Levels	Unit of Measure
2019	Chloroform	1.2	1.2 - 1.2	ppb
2019	Bromoform	11.5	11.5 - 11.5	ppb
2019	Bromodichloromethane	3.9	3.9 - 3.9	ppb
2019	Dibromochloromethane	10.3	10.3 - 10.3	ppb
2019	Dibromoacetic Acid	2.8	2.8 - 2.8	ppb
2019	Bromochloroacetic Acid	1.5	1.5 - 1.5	ppb

**Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

During 2021, Albury Manor Utility Company received all of its water from Harris County M.U.D. No. 401. TX1013289 Harris County M.U.D. No. 401 provided the following water quality information:

Inorganic Contaminants

Year	Contaminant	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Unit of Measure	Source of Contaminant
2020	Fluoride	2.4	2.4 - 2.4	4	4	ppm	Erosion of natural deposits.
2020	Barium	0.074	0.074 - 0.074	2	2	ppm	Erosion of natural deposits.

*Flouride—Although the fluoride level measured by the TCEQ does not exceed the MCL, it does exceed the secondary containment level of 2.0 ppm. At times, the water at your home could exceed this secondary containment level. Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Children may get mottled teeth.

Unregulated Contaminants**

Year	Contaminant	Average of All Sampling Points	Range of Detected Levels	Unit of Measure
2019	Bromoform	6.6	5.2 - 7.9	ppb
2019	Bromodichloromethane	2.4	1.9 - 2.9	ppb
2019	Dibromochloromethane	6.1	5.2 - 7.0	ppb
2019	Dibromoacetic Acid	1.8	1.8 - 1.8	ppb

**Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

Organic Contaminants

Year	Constituent	Highest Level at Any Sampling Point	Range of Detected Levels	MCL	MCLG	Unit of Measure	Source of Contaminant
2021	Total Trihalomethanes	20	20.4 - 20.4	80	n/a	ppb	By-products of drinking water chlorination.
2019	Haloacetic Acids (HAA5)	1.8	1.8 - 1.8	60	n/a	ppb	By-products of drinking water chlorination.

Radioactive Contaminants

Year	Contaminant	Average Level Detected	Range of Detected Levels	MCL	MCLG	Unit of Measure	Source of Contaminant
2011	Gross beta	4.6	4.6 - 4.6	50	0	pCi/l	Erosion of natural deposits
2017	Gross Alpha	3.0	3.0 - 3.0	15	0	pCi/l	Erosion of natural deposits
2011	Combine Radium 226 & 228	2.0	2.0 - 2.0	5	0	pCi/l	Erosion of natural deposits

The drinking water produced by your District exceeds the minimum water quality standards established by the USEPA.

Our Water is safe to drink.